Iren Laboratori S.p.A.
Capitale Sociale i.v. Euro 2.000.000,00
Registro Imprese di Genova, REA n. 417131
Partita IVA e Codice Fiscale 01762460069
irenlaboratori@pec.gruppoiren.it

Società sottoposta a direzione
e coordinamento di IREN S.p.A.
Partita IVA e Codice Fiscale 07129470014

Laboratory Reggio Emilia
Quality System certified according to ISO 9001:2008
Accredited laboratory ACCREDIA LAB N ° 0178

Customer:

Hidroconta S.A.
Crta. Santa Catilina 60
30012 Murcia - Spagna

Collected by: Customer
Samples received by: IrenLab Staff
Beginning of the tests: 17/02/2018

Delivered to the laboratory by: Carrier
Received by the laboratory on: 15/02/2018
End date of analysis: 23/02/2018

Sampled by the customer and under his responsibility

Test Report n° RE0780 issued on 23/02/2018

Sample identification: 2018RE04463
Sample description: Vàlvula Hidromatic

Sampled on: 14/02/2018

Sample type: Material

Parameters	Unit of measurement	Results	Maximum value	Mehod	REC	
Global migration in water	mg/kg	9.8	60	DM n. 174 06/04/2004 GU n. 166 17/07/2004 all. IIIC sez. 1		

Maximum value according to the D.M. issued on 06/04/2004, n. 174, published in GU on 17/07/2004 n. 166, relating to plastics

DECLARATION OF CONFORMITY
Based on the result of the check carried out and limited to the control of the Global Migration referred to in Annex III of the Ministerial Decree 6/4/2004 n. 174 "Regulation on materials and objects that can be used in fixed water collection points, treatment, adduction and distribution of waters intended for human consumption". The material is COMPLIANT (see Attachment).

Head of the Laboratory of Reggio Emilia
Dr. Laura Chesi

ORDINE DEI CHIMICI
Dott.ssa
LAURA
CHESI
N. 213
REGGIO EMILIA

This document exclusively refers to the samples tested and may not be reproduced without the written approval of the Laboratory
The tests marked with * are not accredited by ACCREDIA.
Sampling is excluded from Accreditation

End of the Test Report

RE04463