

**Laboratory Reggio Emilia**

Quality System certified according to ISO 9001:2008  
 Accredited laboratory ACCREDIA LAB N° 0178

Customer:

**Hidroconta S.A.**  
 Crta. Santa Catilina 60  
 30012 Murcia - Spagna

Collected by: Customer  
 Samples received by: IrenLab Staff  
 Beginning of the tests: 17/02/2018

Delivered to the laboratory by: Carrier  
 Received by the laboratory on: 15/02/2018  
 End date of analysis: 23/02/2018

Sampled by the customer and under his responsibility

**Test Report n° RE0777 issued on 23/02/2018**

Sample identification: 2018RE04460  
 Sample description: Válvula de Mariposa

Sampled on: 14/02/2018

Sample type: Material

Parameters	Unit of measurement	Results	Maximum value	Mehod	REC	
Global migration in water	mg/kg	4.4	50	DM n. 174 06/04/2004 GU n. 166 17/07/2004 all. IIIC sez. 1		

Maximum value according to the D.M. issued on 06/04/2004, n. 174, published in GU on 17/07/2004 n. 166, relating to natural and synthetic gums

**DECLARATION OF CONFORMITY**

Based on the result of the check carried out and limited to the control of the Global Migration referred to in Annex III of the Ministerial Decree 6/4/2004 n. 174 "Regulation on materials and objects that can be used in fixed water collection points, treatment, adduction and distribution of waters intended for human consumption". The material is COMPLIANT (see Attachment).

Head of the Laboratory of Reggio Emilia

Dr. Laura Chesì



This document exclusively refers to the samples tested and may not be reproduced without the written approval of the Laboratory  
 The tests marked with \* are not accredited by ACCREDIA.  
 Sampling is excluded from Accreditation

End of the Test Report

